



Product Service

CERTIFICATE

No. Z10 103309 0001 Rev. 00

Holder of Certificate: **Meggitt SA**
Route de Moncor 4
1752 Villars-sur-Glâne
SWITZERLAND

Factory(ies): 103309

Certification Mark:



Product: **Safety components
Sensor and Conditioner**

Model(s): **Measuring chain Sensor, Cable & IPC707**

Parameters: Operating Voltage: 18VDC ... 30VDC
Safety Architecture: Type A, HFT 0

Tested according to: IEC 61508-1:2010 (SIL2)
IEC 61508-2:2010 (SIL2)
IEC 61508-4:2010 (SIL2)
ISO 13849-1:2015 (Cat1, PL c)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: MF93087T
Valid until: 2024-02-11

Date, 2019-02-22 (Jürgen Blum)

