



Product Service

CERTIFICATE

No. Z10 103309 0001 Rev. 01

Holder of Certificate: **Meggitt SA**
Route de Moncor 4
CH-1752 Villars-sur-Glâne
SWITZERLAND

Certification Mark:



Product: **Safety components**
Sensor and Conditioner

Model(s): **Measuring chain Sensor, Cable & IPC707**

Parameters: Operating Voltage: 18VDC ... 30VDC
Safety: Type A, HFT 0
Architecture:

Tested according to: IEC 61508-1:2010 (SIL2)
IEC 61508-2:2010 (SIL2)
ISO 13849-1:2023 (Cat. 1, PL c)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: PF103935T

Valid until: 2029-11-21

Date, 2024-11-25

(Christian Dirmeier)