


Date : 19th July, 2014
Place : BBMB Bhakra

"To whomsoever it may concern"

The vibration monitoring and Airgap monitoring system, Make - Meggitt, model VM600, is supplied by M/s Meggitt India Pvt. Ltd. and installed in units 2 & 5 of 5 x 126 MW Hydro Turbines at Bhakra Left Bank Power House during their RM&U. The system has been installed and commissioned for Unit-2 on 19th July 2013 and Unit-5 on 2nd October 2013, since then the system is working satisfactorily till date.

The further installation of the vibration monitoring and Airgap monitoring system shall be done on the remaining Machines Unit-1, 3 & 4 as per their RM&U schedule.

This certificate has been issued on the request of M/s Meggitt India Pvt. Ltd. for qualification purpose only.


BBMB PP-I 19/7/2014
Addl SE / MTC Bhakra PP-I

Dr. Executive Engineer ~~Operation~~ ntc
Bhakra Left Bank Power House
BBMB PP-I Bhakra PP-I

W. Flock
i.A. J.M. Winkler
Andritz Hydro Pvt. Ltd.

Site Manager
Andritz Hydro Site Office
Bhakra Left Bank Power House